

## Declaration of Conformity


We: Delta Controls Ltd,  
Island Farm Avenue,  
West Molesey  
Surrey  
KT8 2UZ  
England

### Description

Pressure, Pressure Difference and Temperature switches comprising a housing in cast Zinc (Mazak) or Stainless steel, with an integral spring and venting chamber to which is attached a process sensor. Process changes in pressure, pressure difference or temperature applied to the sensor moves a push rod, which passes through the enclosure wall to actuate one or two microswitches.

As the manufacturers of the apparatus, listed, declare under our sole responsibility that the products listed below:- Pressure, Pressure Difference, Temperature Switches:- Series "N" 201 - 209, 281, 231- 234 and 301- 305, 381 and 384, 721 - 723, 731- 733, 771, 741-744, 761 - 764, 781, to which this declaration relates are in conformity with the following relevant harmonised standards for Category 3 products:-

EN 50021:1999

EEx nC II T6  II 3G  
T<sub>amb</sub> (-25 °C to +60 °C)

Self certified by Delta controls Ltd in accordance with Article 9 of the Council Directive 94/9/EC.

And thereby, conforms to the requirements of the ATEX Directive 94/9/EC.

Signed



.....  
R. Harrison  
Managing Director  
Dated 16<sup>th</sup> July 2003

**Delta Controls Limited**  
Island Farm Avenue  
West Molesey  
Surrey  
KT8 2UZ

**T** +44 (0) 20 8939 3500  
**F** +44 (0) 20 8783 1163  
**E** sales@delta-controls.com  
**W** www.delta-controls.com

